



FIRE AND BUILDING CODE ENFORCEMENT INSPECTION REPORT ORDER

DIVISION OF FIRE AND BUILDING SAFETY
INDIANA DEPARTMENT OF HOMELAND SECURITY
302 WEST WASHINGTON STREET, RM E241
INDIANAPOLIS, IN 46204
TELEPHONE: 317-232-2222
WEB ADDRESS: WWW.IN.GOV/DHS

Identification Number DC13842	Name of the facility APPLE TREE CHILD CARE CTR	County DELAWARE
Address of Property 3501 CHADAM LANE MUNCIE 47304	Name of the Contact DIANA BADGER	Telephone Number (765) 286-0616
Email	Inspection Date 11/14/2013	
Inspection Category LICENSED CHILD CARE	Inspection Type ANNUAL	Inspection Status: VIOLATION
Name of the inspector KEVIN TROY	Phone: 3174176656	
Email: ktroy@dhs.in.gov		

Violations

VIO- LATION NUMBER	RULE OR INDIANA CODE SECTION VIOLATED	DESCRIPTION OF VIOLATION	DATE BY WHICH VIOLATION MUST BE CORRECTED
1	Sec. 1015.2 2008 Edition IFC 675 IAC 22-2.4	Required exits shall be located in a manner that makes their availability obvious. Exits shall be unobstructed at all times. Exit and exit access doorways shall be arranged in accordance with Sections 1015.2.1 and 1015.2.2. <u>One of the interior exit doors in Room 16 is blocked by a table.</u>	12/04/2013
2	Sec. 605.1 2008 Edition IFC 675 IAC 22-2.4	Identified electrical hazards shall be abated. Identified hazardous electrical conditions in permanent wiring shall be brought to the attention of the code official responsible for enforcement of the ICC Electrical Code. Electrical wiring, devices, appliances and other equipment that is modified or damaged and constitutes an electrical shock or fire hazard shall not be used. <u>The outlet by the Kids Gym is loose in the wall and needs to be repaired.</u>	12/04/2013
3	Sec. 1011.4 2008 Edition IFC 675 IAC 22-2.4	Internally illuminated exit signs shall be listed and labeled and shall be installed in accordance with the manufacturer's instructions and Section 2702. Exit signs shall be illuminated at all times. <u>The exit signs above the two interior doors in Room 16 are not illuminated.</u>	12/04/2013
4	Sec. 807.1 2008 Edition IFC 675 IAC 22-2.4	In occupancies in Groups A, E, I and R-1 and dormitories in Group R-2, curtains, draperies, hangings and other decorative materials suspended from walls or ceilings shall meet the flame propagation performance criteria of NFPA 701 in accordance with Section 806.2 or be noncombustible. In Groups I-1 and I-2, combustible decorative materials shall meet the flame propagation criteria of NFPA 701 unless the decorative materials, including, but not limited to, photographs and paintings, are of such limited quantities that a hazard of fire development or spread is not present. In Group I-3, combustible decorative materials are prohibited. Fixed or movable walls and partitions, paneling, wall pads and crash	12/04/2013

		<p>pads, applied structurally or for decoration, acoustical correction, surface insulation or other purposes, shall be considered interior finish if they cover 10 percent or more of the wall or of the ceiling area, and shall not be considered decorative materials or furnishings. In Group B and M occupancies, fabric partitions suspended from the ceiling and not supported by the floor shall meet the flame propagation performance criteria in accordance with Section 807.2 and NFPA 701 or shall be noncombustible.</p> <p><u>The decorative materials in Room 5 that are hanging from the ceiling have not been treated for flame spread.</u></p>	
5	Sec. 605.5 2008 Edition IFC 675 IAC 22-2.4	<p>Extension cords and flexible cords shall not be a substitute for permanent wiring. Extension cords and flexible cords shall not be affixed to structures, extended through walls, ceilings or floors, or under doors or floor coverings, nor shall such cords be subject to environmental damage or physical impact. Extension cords shall be used only with portable appliances.</p> <p><u>The microwave in the kitchen is being powered by an extension cord.</u></p>	12/04/2013

Facility Id	Received By Name	Signature and Date
DC13842		

APPEAL RIGHTS

Please be advised that if you desire administrative review of this Order and **this Order was delivered by hand**, you must file a written petition for review with the Fire Prevention and Building Safety Commission at 302 West Washington Street, Rm. W246, Indianapolis, IN 46204, identifying the violations for which you seek review no later than 15 calendar days from the hand delivery date of this Order unless such date is a Saturday, Sunday, legal holiday under state statute, or day that the Department of Homeland Security's offices are closed during regular business hours, in which case the deadline would be the first calendar day thereafter that is not a Saturday, Sunday, legal holiday under state statute, or day that the Department of Homeland Security's offices are closed during regular business hours. If you do so, your petition for review will be granted and an administrative proceeding will be conducted by an administrative law judge appointed by the Fire Prevention and Building Safety Commission. If you do not file a petition for review, this Order will be **FINAL** and you **MUST** comply with its requirements.

Please be advised that if you desire administrative review of **this Order and this Order was delivered by first class U.S. mail**, you must file a written petition for review with the Fire Prevention and Building Safety Commission at 302 West Washington Street, Rm. W246, Indianapolis, IN 46204, identifying the violations for which you seek review no later than 18 calendar days from the mailing date of this Order unless such date is a Saturday, Sunday, legal holiday under state statute, or day that the Department of Homeland Security's offices are closed during regular business hours, in which case the deadline would be the first calendar day thereafter that is not a Saturday, Sunday, legal holiday under state statute, or day that the Department of Homeland Security's offices are closed during regular business hours. If you do so, your petition for review will be granted and an administrative proceeding will be conducted by an administrative law judge appointed by the Fire Prevention and Building Safety Commission. If you do not file a petition for review, this Order will be **FINAL** and you **MUST** comply with its requirements.

Please be further advised that you may request an opportunity to informally discuss this Order prior to filing a petition for review. Such informal discussion, or a request therefor, does not extend the deadline for filing a petition for review and, therefore, any request for an informal discussion should be made promptly, preferably by telephone, upon receipt of this Order.